



Environmental and Laboratory Services

90 1/2 West Blackwell St., Dover, New Jersey 07801

(973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: July 10, 2017

Client: H.W. Mountz Elementary School
Address: 411 Tuttle Avenue
Spring Lake, NJ 07762

Sample description: Drinking Water / 1st Draw / DWS5799-1
Sample location: 1921-DW-2FL-Hallway Rm 202
Sampled by: M. Schwartz
Sample date: 06/25/17
Time: 07:16
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	00:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-2
Sample location: 1921-DW-3FL-Hallway Bathroom
Sample date: 06/25/17
Time: 07:19
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	00:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-3
Sample location: 1921-DW-3FL-Hallway Rm 302
Sampled by: M. Schwartz
Sample date: 06/25/17
Time: 07:20
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	00:52	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-4
Sample location: 1921-DW-1FL-Kitchen
Sampled by: M. Schwartz
Sample date: 06/25/17
Time: 07:22
Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	00:58	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-5
 Sample location: 1921-DW-2FL-Rm 5
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:25
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.58 µg/L	15 µg/L	07/01/17	01:04	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-6
 Sample location: 1971-DW-1FL-Gym-Left
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.11 µg/L	15 µg/L	07/01/17	01:10	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-7
 Sample location: 1971-DW-1FL-Gym-Right
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:29
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.26 µg/L	15 µg/L	07/01/17	01:28	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-8
 Sample location: 1971-DW-1FL-Hallway
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:30
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	01:34	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-9
 Sample location: 1971-DW-1FL-Rm 103
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:31
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	8.01 µg/L	15 µg/L	07/01/17	01:40	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-10
 Sample location: 1971-DW-1FL-Rm 104
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:32

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.29 µg/L	15 µg/L	07/01/17	01:46	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-11
 Sample location: 1971-DW-1FL-Rm 105
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:35
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	01:52	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-12
 Sample location: 1971-DW-2FL-Hallway Left
 Sample date: 06/25/17
 Time: 07:41
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	28.2 µg/L	15 µg/L	07/01/17	02:01	2	4.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-13
 Sample location: 1971-DW-2FL-Hallway Right
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:42
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.75 µg/L	15 µg/L	07/01/17	02:07	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-14
 Sample location: 1971-DW-2FL-Rm 205
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:44
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	02:19	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-15
 Sample location: 1971-DW-2FL-Rm 206
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:45
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	7.29 µg/L	15 µg/L	07/01/17	02:50	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-16
 Sample location: 1971-DW-2FL-Rm 207
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:46
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	5.29 µg/L	15 µg/L	07/01/17	02:56	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-17
 Sample location: 1971-DW-2FL-Rm 208
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:47
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	4.26 µg/L	15 µg/L	07/01/17	03:02	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-18
 Sample location: 1971-DW-2FL-Rm 209
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:48
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	03:08	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-19
 Sample location: 1971-DW-2FL-Rm 210
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:49
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	2.57 µg/L	15 µg/L	07/01/17	03:14	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-20
 Sample location: 1971-FP-1FL-Kitchenette
 Sampled by: M. Schwartz
 Sample date: 06/25/17
 Time: 07:53
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	03:20	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-21
 Sample location: 1971-NS-1FL-Nurse
 Sampled by: M. Schwartz
 Sample date: 06/23/17
 Time: 07:55
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	6.17 µg/L	15 µg/L	07/01/17	03:25	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-22
 Sample location: 2001-DW-1FL-Rm 107
 Sampled by: M. Schwartz
 Sample date: 06/23/17
 Time: 07:56
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	03:31	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-23
 Sample location: 2001-DW-1FL-Rm 108
 Sampled by: M. Schwartz
 Sample date: 06/23/17
 Time: 07:57
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	03:37	1	2.00 µg/L

Sample description: Drinking Water / 1st Draw / DWS5799-24
 Sample location: Field Blank
 Sampled by: M. Schwartz
 Sample date: 06/23/17
 Time: 07:10
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	07/01/17	03:43	1	2.00 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan Van Veen
 Susan Van Veen, Lab Manager
 NJ Laboratory Certification ID # 14013

July 20, 2017
 Date